



CUCAMONGA VALLEY WATER DISTRICT
Recycled Water Guidelines for On-Site Grading & Dust Control

Requirements: For Temporary Recycled Water Use On Site

- A) Customer shall call or come into CVWD Engineering Department to make sure recycled is available in a specific location.
- B) A CVWD Recycled Water Permit must be filled out & approved by CVWD for on-site recycled water use.
- C) CVWD recycled water meter shall be checked out for the site.
- D) Shall have a "Site Supervisor" designated for the site.
- E) CVWD shall conduct a Tailgate meeting with all on site personal using the recycled water, before any recycled water may be used on site.
- F) All water trucks, water tanks, hoses, or any other materials used for the use of recycled water, shall be well marked with place cards & recycled water tape marked " Recycled Water Do Not Drink " in English & in Spanish.
- G) Recycled Water signs 8.50 high by 11.00 wide shall be placed at all entrances of the construction site, including the construction office. Signage must be approved by CVWD.
- H) There shall not be any type of recycled water run-off or over spray at the site. Sand bags may be used to control this from happening or any other means of run-off control.

Property owner or Contractor

Date

Shane Stevens
Recycled Water Coordinator
Cucamonga Valley Water District
shanes@cvwdwater.com Phone# 909/987-2591